

Warranty Track

1. Generate NOA (Award Quote) ✓
2. Request Tech Review ✓
3. Request Inspection
4. Request Warranty



ASSEMBLY LETTER

October 15, 2025

To: SoCo Roofing
321 S. Crosslane Road
Monroe, GA 30656

Phone: (678) 425-9010

Contact: Christie Zoller
christie@socoroofingservices.com

On 10/03/2025 we received your Notice of Award for a Sika Corporation Application at:

Project Name: **Tanger Outlet Huntsville AL Building 300**

Address: **365 The Bridge St. NW**
Huntsville, AL 35806

Region: **Southeast**

Building Group Name	Square Footage	Building Usage	Primary Membrane	System	Windspeed	Warranty
Main Roof	58,000	Commercial - Shops & Markets	SPL Fastened-60 Felt Wht6112 10ftx 100ft	Sikaplan Fastened (Disc Attached)	60 mph (97 km/h)	20 Year Sikaplan Sys. Plus Warranty

From this date forward this Project Number is: **ON00508219**

Michael Rauth
Technical Sales Representative
rauth.michael@us.sika.com

Terry Labate
labate.terry@us.sika.com

Jeremy Bugbee
Assistant Regional Technical Manager
bugbee.jeremy@us.sika.com
(678) 218-8610

Ricardo Hartley
Regional Technical Manager - Southeast
hartley.ricardo@us.sika.com
(678) 672-7993

Perry Thomas
Technical Service Representative
thomas.perry@us.sika.com
(770) 841-0184

- Sika's review of the Notice of Award submitted is done strictly for the purposes of determining whether a Sika warranty could be issued upon successful installation of the proposed assembly. Sika does not review the information submitted for compliance with building or other codes, regulations, insurance or any other requirement.
- Deviations from the accepted notice of award, including any plans for any overburden may prevent the job from being warranted by Sika.

Warranty Track

1. Generate NOA (Award Quote) ✓
2. Request Tech Review ✓
3. Request Inspection
4. Request Warranty



- For a Systems Warranty, use only Sika Sarnafil supplied components. Only those components supplied by Sika Sarnafil are covered under the warranty.*
*In recover applications, existing components including attachments are excluded from Sika's warranty coverage.
- Projects requiring a Membrane warranty are not inspected and cannot be changed to a system warranty after the project begins.
- Use only Sika published details, submit any non-standard (not in catalog) details for technical review prior to installation.
- In all future correspondence please include the project number referenced above.

Refer to the Product Data Sheet, Safety Data Sheet, Applicator Handbook, Sika published literature, or call Technical for specific questions on any of the products listed below. Product & Safety data sheets can be found at:

<https://usa.sika.com/sarnafil/en/downloads.html>

COMMENTS:

Membrane Base Securement

- Secure membrane with SPL Disc 12-inches o.c at the base of a wall, a curb or angle change.
- Secure membrane with a minimum four (4) SPL Disc at the base of a pipe-style penetration.

Membrane Flashing & Roof Edge Securement

- Install flashing in accordance with Sika's [typical details](#) or [system specific details](#).
- Edge metal shall be designed in accordance with the [ANSI/SPRI standards](#).

Recover Preparation

- Replace wet areas identified in moisture survey.
- Cut existing single-ply membrane free at perimeter edge, penetrations, curbs and walls.

System Cross Section

Main Roof				
Product	New?	Field	Perimeter	Corner
Sarnafastener XP	True			
Sikaplan Disc 2-3/8 inch Eye-Hook	True	10' rows @ 12 in. o.c.	5' rows @ 12 in. o.c.	See detail MF-PE1 @ 12 in. o.c.
Sikaplan Fastened 60 mil 10x100ft White FELT	True			
Existing Single-Ply Membrane	False			
Existing Insulation	False			
DECK - Metal	False			

DISCLAIMER: The information contained in this document, including but not limited to any recommendations regarding the use and application of Sika Corporation ("Sika" or "Sika Sarnafil") products, is given in good faith based on Sika's current experience and knowledge of its products when properly stored, handled and applied under normal conditions in accordance with Sika's instructions. The information contained in this document is valid only for the applications and uses of Sika products described herein. Any deviation from any of the instructions, uses, applications and recommendations contained in this document regarding the Sika products will void any Sika warranty. The user of the Sika products is solely responsible for determining the suitability of each product for the intended application and purpose. Prior to each use of any Sika product, the user must always read and follow the warnings and instructions on the product's current Technical Data Sheet, label and Material Safety Data Sheets available at <https://usa.sika.com/sarnafil/en/downloads.html>. If project is a waterproofing application Sika strongly recommends that the Authorized Waterproofing Applicator submit shop drawings well prior to the job start for review by the Sika technical department to determine if the details are warrantable. If shop drawings are not submitted, the Applicator acknowledges that a Sika system waterproofing or single-source green roof warranty may not issue for the project and a membrane warranty will be provided if non-warrantable details are installed. Alternatively, changes to the details while the job is in progress may be needed which may require different products and additional training. This may result in extensive delays to the project. Correcting installed non-warrantable details to a warrantable condition, and all associated costs, are the applicators responsibility. All sales of Sika products are subject to its current terms and conditions of sale available at <https://usa.sika.com/sarnafil/en/terms-conditions-of-sale.html>.